



KENNEDY VALVE

Division of McWane, Inc.

1021 East Water Street

P.O. Box 931

Elmira, New York 14902-0931

Telephone (607) 734-2211

Fax (607) 734-1003

Certificate of Compliance

[2.5 - 6" G300(IG) / G300E(IG) & W300IG Butterfly Valves]

This is to certify that the 2.5" - 6" Kennedy Valve models G300(IG) Grooved End, G300E(IG) Extended Length Grooved End and W300(IG) Wafer Style Butterfly Valves manufactured by Kennedy Valve located in Elmira New York, USA, are rated to 300 psi and meet all dimensional, material, and testing requirements, per the latest edition of UL1091 and FM1112 standards.

The interior and exterior surfaces of the valves are coated with an approved Heat Fused Powder Epoxy which meets the requirements of AWWA C550 (Protective Interior Coatings for Valves and Hydrants) and has been tested and accepted by UL.

Valves are Seat and Shell tested to 600 psi and are operated through a minimum of one complete cycle. The switches are electrically tested for functionality and mechanically designed to monitor the valve open position and approved for indoor and outdoor fire protection service.

All valves have ductile iron discs that are fully encapsulated with EPDM rubber. The adhesion/bond of the rubber to metal disc have been tested per ASTM D429 and meet the applicable requirements of ASTM D2000.

Wafer style Butterfly Valves conform to the face to face requirements of MSS SP-67

October 7, 2022

Daniel Burczynski

Kennedy Valve Quality Manager

ISO 9001:2015 Certified

ISO 14001:2015 Certified