



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

Kennedy Valve
1021 E Water St
Elmira, NY 14901, United States

Plant Location:

Elmira, NY, United States

Standards:

NSF/ANSI/CAN 61 - 2023
NSF/ANSI/CAN 372 - 2023

Certificate:

Issued Date: 06/03/2025

Material/Product:

Rotating Disc Gate Valve

Contact Temperature:

23 ± 2°C

Models:

Series 42 FLG NRS Rotating Disc Gate Valves 3-48" [1,2]
Series 49 FLG OS&Y Rotating Disc Gate Valves 3-48" [1,2]
Series 52 FLG NRS Rotating Disc Gate Valves 3-48" [1,2]
Series 525 FLG x MJ NRS Rotating Disc Gate Valves 3-48" [1,2]
Series 55 MJ NRS Rotating Disc Gate Valves 3-48" [1,2]
Series 59 FLG OS&Y Rotating Disc Gate Valves 3-48" [1,2]

[1] Certified for equivalent metric sizes.

[2] Certified for distribution systems only.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.